

SUBJECT: Location of Appliance Shutoff Valves

EFFECTIVE DATE: May 2002 **REVISED:** July 2004

INTERPRETATION NUMBER: ADM – 3.0303.1

SEE ALSO: 2000 UMC – Section 303.1

INTERPRETATION SUMMARY

This section requires that appliance shutoffs are to be located in an accessible location within 6' of the appliance and in the same room or space. It is our interpretation that a valve located in a closet or space contiguous with and accessory to the room where the appliance is located is acceptable.